



QUADRUPLE SERVICE MANIFOLD

NOT TO SCALE

NOTES:

1. USE GATE VALVE SERVICE CONNECTION SEE DETAIL 701.
2. FOR 5/8" x 3/4" METER SETTERS, 2" MANIFOLD SHALL BE 12" LONG.
FOR 1" METER SETTERS, 2" MANIFOLD SHALL BE 12" LONG.
3. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SIZE SHALL BE 3/4" FROM BUSHING AT TEE.
FOR 1" METER SETTERS, MANIFOLD SIZE SHALL BE 1" FROM BUSHING AT TEE.
4. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SHALL BE 12" LONG.
FOR 1" METER SETTERS, MANIFOLD SHALL BE 12" LONG.
5. FOR 5/8" x 3/4" METER SETTERS, USE 2-17"x30" METER BOXES AS SHOWN.
FOR 1" METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE DETAIL 703.
6. THE METER BOXES SHALL BE CENTERED OVER THE METER SETTER ASSEMBLIES AS SHOWN.

APPROVED: LYNN ARAKAKI

REV. DATE: NOV. 01, 2005

WATER/WASTEWATER DIVISION



STANDARD DETAILS

**QUADRUPLE SERVICE
MANIFOLD**

FILE SD703C.DGN | DRAWING NO. **703C**